

IO-Link

Product Quality Policy

Version 1.80
June 2026

Order No: 10.132

File name: IO-Link-Product_Quality_Policy_10132_V180_Jun26

This document has been prepared, approved, and released by the IO-Link Steering Committee.

Important notes:

NOTE 1 The IO-Link Community Rules shall be observed prior to the development and marketing of IO-Link products. The document can be downloaded from the www.io-link.com portal.

NOTE 2 Any IO-Link Device shall provide an associated IODD file. Easy access to the file and potential updates shall be possible. It is the responsibility of the IO-Link Device manufacturer to test the IODD file with the help of the IODD-Checker tool available per download from www.io-link.com.

NOTE 3 Any IO-Link devices shall provide an associated manufacturer declaration on the conformity of the device. A corresponding form with references to relevant documents is available per download from www.io-link.com.

The information contained in this document is subject to change without notice. The material in this document details a PNO specification in accordance with the license and notices set forth on this page. This document does not represent a commitment to implement any portion of a PNO specification in any company's products.

The attention of adopters is directed to the possibility that compliance with or adoption of PNO specifications may require use of an invention covered by patent rights. PNO shall not be responsible for identifying patents for which a license may be required by any PNO specification, or for conducting legal inquiries into the legal validity or scope of those patents that are brought to its attention. PNO specifications are prospective and advisory only. Prospective users are responsible for protecting themselves against liability for infringement of patents.

WHILE THE INFORMATION IN THIS DOCUMENT IS BELIEVED TO BE ACCURATE, PNO MAKES NO WARRANTY OF ANY KIND, EXPRESS OR IMPLIED, WITH REGARD TO THIS DOCUMENT INCLUDING, BUT NOT LIMITED TO ANY WARRANTY OF TITLE OR OWNERSHIP, IMPLIED WARRANTY OF MERCHANTABILITY OR WARRANTY OF FITNESS FOR PARTICULAR PURPOSE OR USE.

In no event shall PNO be liable for errors contained herein or for indirect, incidental, special, consequential, reliance or cover damages, including loss of profits, revenue, data or use, incurred by any user or any third party. Compliance with PNO specifications does not absolve manufacturers, from the requirements of safety and regulatory agencies (TÜV, BIA, UL, CSA, etc.).

USE OF TRADEMARKS:

 **IO-Link**® is registered trade mark. The use is restricted for members of the IO-Link Community. More detailed terms for the use can be found in the IO-Link Community Rules on www.io-link.com.

PNO is the owner of several registered trademarks, such as PROFIBUS®, PROFINET®, omlox®, IO-Link®, MTP® and others. More detailed terms for the use can be found on the web page www.profibus.com. Please select buttons "Downloads / Presentations & logos". In some cases, PNO is the licensee of registered trademarks owned by third parties and which may be relevant in regard with products compliant to this document.

PNO shall always be the sole entity that may authorize developers, suppliers and sellers of hardware and software to use certification marks, trademarks or other special designations to indicate compliance with a PNO specification. Products developed using a PNO specification may claim compliance or conformance with a PNO specification only if the hardware and/or software satisfactorily meets the certification requirements set by PNO. Products that do not meet these requirements may claim only that the product was based on a PNO specification and must not claim compliance or conformance with a PNO specification.

COPYRIGHT

Copyright © 2025 PROFIBUS Nutzerorganisation e.V.

Any unauthorized use of this publication may violate Copyright Law, Trademark Law and other legal regulations. This document contains information which is protected by Copyright. No part of this work covered by Copyright herein may be reproduced or used in any form or by any means -graphic, electronic, or mechanical, including photocopying, recording, taping, or information storage and retrieval systems--without permission of the publisher.

Publisher:

IO-Link Community

c/o PROFIBUS Nutzerorganisation e.V.

Ohiostrasse 8

76149 Karlsruhe

Germany

Phone: +49 721 / 98 61 97 0

Fax: +49 721 / 98 61 97 11

E-mail: info@io-link.com

Web site: www.io-link.com

LICENSE AGREEMENT

1. License

1.1 Subject of this license agreement is this document issued by the Licensor, in electronic form. If applicable, also software may be provided.

1.2 The user of this document (Licensee) acquires the license solely from PROFIBUS Nutzerorganisation e.V., having its principal place of business in Karlsruhe, Germany (hereinafter referred to as "Licensor").

1.3 This document is not an industrial standard acknowledged by any standardization body or otherwise and may be further enhanced.

2. Rights and Duties of Licensee

2.1 Licensor hereby grants to Licensee the right to use this document exclusively for developing and supporting products compliant with this document. Licensee may copy this document for this purpose and for data backup purposes.

2.2 Licensee shall not be entitled to modify, decompile, reverse engineer or extract any individual parts of this document, unless this is permitted by mandatory Copyright Law. Furthermore, Licensee shall not be entitled to remove any alphanumeric identifiers, trademarks or copyright notices from this document and, insofar as Licensee is entitled to make copies of this document, Licensee shall copy them without alteration.

2.3 Licensee is not entitled to copy and redistribute this document to any third party, except for "Have Made" purposes. All copies must be obtained on an individual basis, directly from the website www.profibus.com or upon request from the Licensor.

2.4. Licensee agrees to comply with all applicable export control, trade, and sanctions regulations as well as embargo regulations of the European Union, the United States of America, and other relevant jurisdictions ("Export Control Regulations"). This applies in particular to the applicable Export Control Regulations relating to Russia and Belarus and with natural or legal persons associated with Russia and Belarus. Should Licensor become aware of any violation of Export Control Regulations with respect to the use of this document, PNO reserves the right to terminate this Agreement without notice and claim damages.

3. Liability of Licensor

3.1 Licensor shall have no obligation to enhance the document and shall assume no liability in case the document or future versions thereof shall not be approved as an industrial standard.

3.2 Licensor's liability for defects as to quality or title of this document, especially in relation to the correctness or absence of defects or the absence of claims or third-party rights or in relation to completeness, usability and/or fitness for purpose are excluded, except for cases involving gross negligence, willful misconduct or fraudulent concealment of a defect.

3.3 Any further liability is excluded unless required by law, e.g. in cases of personal injury or death, willful misconduct, gross negligence, or in case of breach of fundamental contractual obligations. The damages in case of breach of fundamental contractual obligations is limited to the contract-typical, foreseeable damage if there is no willful misconduct or gross negligence.

4. Place of Jurisdiction and Applicable Law

4.1 The sole place of jurisdiction shall be the principal place of business of Licensor.

4.2 All relations arising out of the contract shall be governed by the substantive law of Germany, to the exclusion of the United Nations Convention on Contracts for the International Sale of Goods (CISG).

Conventions:

In this specification the following key words (in **bold** text) will be used:

shall:	indicates a mandatory requirement. Designers shall implement such mandatory requirements to ensure interoperability and to claim conformity with this specification.
should:	indicates flexibility of choice with a strongly preferred implementation.
can:	indicates flexibility of choice with no implied preference (possibility and capability).
may:	indicates a permission.
highly recommended:	indicates that a feature shall be implemented except for well-founded cases. Vendor shall document the deviation within the user manual and within the manufacturer declaration.

CONTENTS

Management summary – scope of this document	5
Overview of related documents	5
Terms, definitions, and abbreviated terms.....	6
3.1 Terms and definitions.....	6
3.2 Symbols and abbreviated terms	7
Manufacturer declaration	7
4.1 General rules	7
4.2 The way to manufacturer declaration (MD).....	8
4.2.1 Steps for IO-Link members	8
4.2.2 Steps for non-IO-Link members (licensee)	8
4.2.3 Steps for publishing MD.....	8
4.3 Additional procedures regarding re-testing	8
4.3.1 General approach	8
4.3.2 Devices	9
4.3.3 Masters	9
Testing and test tools.....	9
5.1 Prerequisites for type testing	9
5.2 Test of an IODD (only for Devices).....	9
5.3 Test of the physical layer (PL) and EMC	10
5.4 Test of the Protocol.....	10
5.5 Tools for testing	10
Quality center	11
Bibliography.....	12
 Figure 1 – Related documents	 5
 Table 1 – Subject of IO-Link's technical and policy documents.....	 6
Table 2 – Consequences of changes to the Device interface	9
Table 3 – Consequences of changes to the Master interface	9
Table 4 – Prerequisites for type testing	9

IO-Link Product Quality Policy – Organization and procedures

Management summary – scope of this document

This policy describes the necessary procedures on how to attain a manufacturer declaration for an IO-Link Master or Device and shall ensure the product quality.

Furthermore, in clauses 4 and 5 it gives hints

- for the successful preparation of testing,
- steps to create a manufacturer declaration,
- for brand labelling.

Overview of related documents

The IO-Link Community uses a set of policies to organize work of its members, providers, and test centers and to maintain quality assurance (mainly interoperability) of member products as shown in Figure 1. The technical specifications ([2], [3], and [4]) are building a technical platform for a certain generation of Devices and Masters. Consistent versions of the specifications are bundled to a Package and supposed to stay stable for several years.

The quality of products is stated only by a Manufacturer Declaration based on tests and referenced test reports.

All IO-Link implementations shall use valid specifications at that time. All valid specifications and documents are available on IO-Link.com and listed in [11]




Figure 1 – Related documents

Table 1 provides information on IO-Link's technical and policy documents.

30

Table 1 – Subject of IO-Link's technical and policy documents

Title of document	Subject	Ref
IO-Link Interface and System	Specification of IO-Link interface, communication, and engineering technology	[1], [2]
IO-Link IO Device Description	Specification of IO-Link Device parameters in a formal language (XML)	[3]
IO-Link Test	Specification of TestCases for physical tests and behavioral tests for Devices and Master	[4]
IO-Link Community Rules (Body of rules between IO-Link members and the PNO)	This document governs the cooperation between IO-Link members or licensees and the PNO and describes the rights and obligations of the partners.	[5]
IO-Link License Model	This document describes the license model for non-IO-Link members.	[6]
Quality of Services Agreement	This document is an agreement between IO-Link Community and the IOL-Competence Centers (IOLCC) for the technologies of IO-Link to assure quality of services.	[7]
Test Center Guideline	This document describes the preconditions for becoming a test laboratory approved by IO-Link community. It additionally describes the rules for the performance of such an IOL Test Center (IOLTC).	[8]
IO-Link Exceptions	This document describes the change and exception management in case of implementation or test deviations.	[9]
Confirmation of completion of conformance tests	This document is the test confirmation of an IOL Test Center (IOLTC) or a brand label provider.	[10]
Specifications validity periods	The document provides an overview of available IO-Link specifications and rules their current status of validity within the life cycle.	[11]
Package	Set of specifications	[12]

31

32 Terms, definitions, and abbreviated terms

33 3.1 Terms and definitions

34 For the purposes of this document, the terms and definitions given in [2], [3], and [4], as well
 35 as the following apply.

36 3.1.1

37 IO-Link specifications

38 This are system specification, system extensions, profile specifications, IODD specification and
 39 related test specifications

40 3.1.2

41 IO-Link Service Center

42 Central office of the IO-Link community, see publisher

43 3.1.3

44 Approved component list

45 The Approved component list comprises all devices with available IODDs by publishing the MD
 46 on the community hosted IODDfinder and all masters by publishing the MD on the community
 47 hosted Approved component list (ACL)

48 3.1.4

49 Master Tester

50 Tool, intended to perform test cases for IO-Link Master according to the IO-Link test specifica-
 51 tion, approved by IO-Link quality authorities

3.1.5**Device Tester**

Tool, intended to perform test cases for IO-Link Devices according to the IO-Link test specification, approved by IO-Link quality authorities

3.1.6**IODD**

electronic I/O and parameter description in XML of an IO-Link Device for its configuration and parameterization to match certain application requirements

3.1.7**DeviceID**

unique IO-Link Device identification allocated by a vendor

3.1.8**VendorID**

unique vendor identification assigned by the IO-Link Community

3.1.9**MasterID**

unique IO-Link Master identification allocated by a vendor

3.2 Symbols and abbreviated terms

IOLCC	IO-Link Competence Center
IOLTC	IO-Link Test Center
DUT	Device under test
MD	Manufacturer declaration

Manufacturer declaration**4.1 General rules**

- The Manufacturer Declaration states compliance to the IO-Link specifications.
- The MD templates from the website IO-Link.com shall be used.
- The MD shall be signed by vendors.
- The MD shall be made available to customers by adding to the Approved component list.
- For the reason of functionality and interoperability, the implementation of the common profile (part identification and diagnosis) is highly recommended.
- Profiles shall be implemented and tested according to the profile specifications.
- Brand labeled products require the Vendor ID (VID) of the branding company.

Important note:

Exceptions for not implemented "highly recommended" features specified in [2] or profiles shall be documented within the user manual and the manufacturer declaration.

- Exceptions against the IO-Link specifications shall be handled according to the rules defined in [9].
- Members are entitled to perform the required tests under their own responsibility. The Manufacturer Declaration has no expiring date.
- Non-members are obliged to provide a signed document "Confirmation of completion of conformance tests" [11] to the IO-Link Service Center to get an IO-Link licence. See IO-Link License Model [6].
- For extensions like IO-Link Safety or IO-Link Wireless different MDs may be required.

4.2 The way to manufacturer declaration (MD)

The preconditions for an MD are:

- Each family of Devices or Masters shall be well defined to be listed later in the MD,
- Prerequisites for Devices are VendorID, DeviceID and IODD,
- Prerequisite for Masters are VendorID and MasterID

4.2.1 Steps for IO-Link members

- 1) Execute IO-Link conformance to specifications and test specifications.
- 2) Fill out and sign the MD.
- 3) Add the MD to the Approved component list.

4.2.2 Steps for non-IO-Link members (licensee)

- 1) Contact an IO-Link Test Center or the brand label provider to get the "Conformance test commitment for licences" to apply for a VendorID (see [6]).
- 2) Apply for a VendorID at the IO-Link Service Center.
- 3) Ask IO-Link Test Center or the brand label provider for the "Confirmation of completion of conformance tests" (see [10]).
- 4) Fill out and sign the MD.
- 5) Provide the MD and the "Confirmation of completion of conformance tests" (see [10]) to the IO-Link Service Center to get the licence.
- 6) Add the MD to the Approved component list.

4.2.3 Steps for publishing MD

For devices upload the IODD and MD within a ZIP file to the IODDfinder.

For masters send MD to info@io-link.com to be added to the ACL.

4.3 Additional procedures regarding re-testing

4.3.1 General approach

This clause describes the recommendations for re-testing whenever changes have been made at an already tested Device or Master. Either a full test or a partial test shall be performed. This leads to a new test report and a corresponding MD.

Due to the increasing complexity of Device variants, the following clause can only cope with fundamental deviations of the IO-Link interface (communication and/or timing). Other deviations should be negotiated between manufacturer and an IOLTC.

4.3.2 Devices

Table 2 shows the consequences of fundamental changes/deviations in a Device.

Table 2 – Consequences of changes to the Device interface

Changes/deviations	New DeviceID	Physical layer test	EMC test	Protocol test	New MD
Software changes in application new functions / parameters	X			X	X
Software changes influencing communication / timing	X	X		X	X
Hardware changes influencing communication		X	X		X
NOTE Communication software is part of the Device software, which represents the implementation of the protocol layers, data objects, methods and interfaces as defined in [2].					

4.3.3 Masters

Table 3 shows the consequences of fundamental changes/deviations in a Master.

Table 3 – Consequences of changes to the Master interface

Changes/deviations	New MasterID	Physical layer test	EMC test	Protocol test	New MD
Software changes influencing communication / timing	X	X		X	X
Hardware changes influencing communication		X	X	X	X
NOTE Communication software is part of the Master software, which represents the implementation of the protocol layers, data objects, methods and interfaces as defined in [2].					

Testing and test tools

5.1 Prerequisites for type testing

Table 4 shows the prerequisites for type testing of Device and Master. For testing the latest test systems related to the Package shall be used. The Package and the document “Specifications Validity Periods” [11] are published on IO-Link.com.

Table 4 – Prerequisites for type testing

Type	Final product before release	IODD (checked, stamped)	VendorID	DeviceID	MasterID
Device	X	X	X	X	–
Master	X	–	X	–	X

5.2 Test of an IODD (only for Devices)

Every Device manufacturer shall provide an IODD file for the DUT. The IODD describes the features of a Device (I/O data structures and parameters), which are also used by Device testers for protocol tests.

The correctness of the IODD file shall be tested with the help of the actual version of the IODD checker.

5.3 Test of the physical layer (PL) and EMC

The PL and EMC tests shall be performed according to [2] and [4].

5.4 Test of the Protocol

The protocol test shall be performed according to [4]. In case of Devices a checked IODD shall be used for the test.

5.5 Tools for testing

There are several test systems on the market supporting tests and generating test reports, which are approved by the IO-Link quality authority.

These test systems comprise

- Physical layer Tester
- EMC tester
- Device Tester (protocol)
- IODD checker
- Master tester

Quality center

The IO-Link community is operating a Quality Center for the clearing of MD relevant quality complaints.

Complaints shall be reported in english language via e-mail to quality@io-link.com.

Bibliography

- [1] IEC 61131-9, Programmable controllers – Part 9: *Single-drop digital communication interface for small sensors and actuators (SDCI)*
- [2] IO-Link Community, *IO-Link Interface and System*, Order No. 10.002
- [3] IO-Link Community, *IO Device Description (IODD)*, Order No. 10.012
- [4] IO-Link Community, *IO-Link Test*, Order No. 10.032
- [5] IO-Link Community, *IO-Link Community Rules (Body of Rules)*, Order No. 3.702
- [6] IO-Link Community, *IO-Link License Model*, Order No. 10.302
- [7] IO-Link Community, *IO-Link Quality of Services Agreement*, Order No. 10.052
- [8] IO-Link Community, *IO-Link Test Center Guideline*, Order No. 10.142
- [9] IO-Link Community, *IO-Link Exceptions*, on IO-Link.com, Order No. 10.332
- [10] IO-Link Community, *Confirmation of completion of conformance tests*, Order No. 10.412
- [11] IO-Link Community, *Specifications validity periods* on IO-Link.com Order No. 10.312
- [12] IO-Link Community, *Packages* on IO-Link.com
-

© Copyright by:

IO-Link Community

c/o PROFIBUS Nutzerorganisation e.V.

Ohiostrasse 8

76149 Karlsruhe

Germany

Phone: +49 721 / 98 61 97 0

Fax: +49 721 / 98 61 97 11

E-mail: info@io-link.com

Web site: www.io-link.com



IO-Link